

REVISIONS			
DESCRIPTIONS	BY	DATE	APPROVED

	DEVELOPMENT TYPE	SLOPE<2%	2% TO 10%	>10%
RESIDENTIAL	20,000 sq.ft. LOTS (1858m ²)	0.30	0.38	0.43
	10,000 sq.ft. LOTS (929m ²)	0.35	0.43	0.50
	6,000 sq.ft. LOTS (557m ²)	0.40	0.50	0.60
	APARTMENTS AND MOBILE HOME PARKS *	0.45	0.55	0.65
	COMMERCIAL	0.60	0.70	0.80
	INDUSTRIAL	0.50	0.60	0.70
RURAL	DENSE NATURAL VEGETATION OR CULTIVATED AREAS	0.10	0.20	0.25
	MODERATE VEGETATION	0.15	0.25	0.30
	SPARSE VEGETATION	0.20	0.30	0.35
	PAVED AREAS	0.85	0.90	0.95
	BUILDINGS	100%		

* WHERE LARGE AREAS ARE LANDSCAPED, DETERMINE RUNOFF COEFFICIENT BY SUMMATION OF AREA TYPE TIMES FACTOR FOR TYPE OF AREA.

TABLE TAKEN FROM: STORM DRAIN STUDY, CENTRAL COAST ENGINEERING, APRIL 1976

DRAWN BY: C.A.C.	CITY OF PASO ROBLES ENGINEERING DIVISION	DRAWING NO. E-1
DESIGNED BY:		
DATE: 4/18/94	COEFFICIENT OF RUNOFF TABLE	
FILE NAME: PR-E-1.DWG		